



NOTES:

- ① RED CONCRETE ENCASEMENT IS TO CLASS 'B' CONCRETE (A MIXTURE OF A MINIMUM OF 5 POUNDS OF RED COLORING PER BAG OF CEMENT).
- ② STOP CONCRETE ENCASEMENT AND EXTEND ALL HORIZONTAL CONDUITS 5'-0" BEYOND ENCASEMENT FOR FUTURE CONNECTIONS. PLUG CONDUITS WITH CONDUIT PLUGS ON EACH END.

DUCT BANK SECTION

NTS



ELECTRICAL DETAILS

APPROVED BY: *Shandagiri*
DESIGN MANAGER

EFF. DATE: 12-22-2020	REF. NO. 112
--------------------------	-----------------