



PIPE SIZE	"A" Plugs & Tees	"B" 90° Bend	"C" 45° Bend	"D" 22° 30' Bend	"E" 11° 15' Bend
10"	2'-0"	2'-3"	2'-0"	2'-0"	2'-0"
12"	2'-8"	3'-0"	2'-3"	2'-3"	2'-3"
16"	3'-6"	4'-3"	3'-0"	2'-6"	2'-6"
20"	4'-3"	5'-0"	4'-0"	3'-0"	2'-6"

NOTES:

1. Heights of all Blocks shall be equal to "A", "B", "C", "D", or "E" dimension called for.
2. All concrete to be poured against firm undisturbed soil.

THRUST BLOCK DETAILS

SCALE: NTS



MECHANICAL DETAILS

APPROVED BY: *Shandagiri*
DESIGN MANAGER

EFF. DATE: 12-22-2020 REF. NO. 96