



* SEE SPECIFICATION
SECTIONS 02425 AND
02517

TUNNEL DETAIL

(FOR WATER MAINS LESS THAN 36 INCHES WITH
STEEL CASING OR STEEL RIBS AND LADDING)

NOTES:

1. DETAIL IS FOR PVC PIPE (PRESTRESSED CONCRETE CYLINDER PIPE, STEEL PIPE, AND D.I.P. ALTERNATE SIMILAR).
2. MINIMUM CLEARANCES SHOWN ON THE PLAN & PROFILE DRAWINGS ARE TO THE O.D. OF TUNNEL LINER. ADJUST PROFILE AS REQUIRED TO MAINTAIN CLEARANCES IDENTIFIED. NO SEPARATE PAY.
3. CONTRACTOR TO PROVIDE SUBMITTAL OF THE TUNNEL LINER DESIGN SIGNED AND SEALED BY A PROFESSIONAL ENGINEER.



TUNNEL & CASING DETAILS

APPROVED BY: *Shandagiri*
DESIGN MANAGER

EFF. DATE: 12-22-2020 REF. NO. 42