



FIBERGLASS MANHOLE
STEPS (TYP)

MANHOLE STEP DETAIL

NOTES - MANHOLE STEPS:

1. PROVIDE STEPS PER SPECIFICATION SECTION 02082.
2. BOTTOM MANHOLE STEP SHALL BE NO HIGHER THAN 12" ABOVE MANHOLE INVERT.

TABLE 1 - Manhole Size

Water Main Diameter	MH Size
<30"	60"
30"-36"	60"
>36"	72"



COMBINATION AIR VALVE & DETAILS

APPROVED BY: *Shandagiri*

DESIGN MANAGER

EFF. DATE: 12-22-2020 REF. NO. 57