



AIR RELEASE VALVE DETAIL

SCALE: NTS

NOTES:

1. PROVIDE COMBINATION AIR VALVE PER TECHNICAL SPECIFICATION SECTION 15111 - "AIR RELEASE AND VACUUM RELEASE VALVES (WRF AND PLANT WORK)."
2. ADD INSULATION (DIELECTRIC) GASKET AS NEEDED BETWEEN SERVICE SADDLE AND PIPE. ADD INSULATING (DIELECTRIC) MATERIAL BETWEEN STAINLESS STEEL PIPE AND CAV.
3. PIPE DIAMETER IS TO BE SIZED TO MATCH THE AIR RELEASE VALVE INSTALLED AT THIS LOCATION.



MECHANICAL DETAILS

APPROVED BY: *Shandagiri*
DESIGN MANAGER

EFF. DATE: 12-22-2020	REF. NO. 92
--------------------------	----------------