


NOTES:

1. LOCATE FLUSHING HYDRANTS AS SHOWN ON PLANS.
2. ON OPEN-DITCH ROADWAYS OR OTHER CORRIDORS, SET THE FLUSHING HYDRANTS WITHIN 3 FEET OF RIGHTS-OF-WAY LINES, EASEMENT LINE OR AS SHOWN ON PLANS.
3. THE FLUSHING HYDRANT STEAMER NOZZLE SHALL FACE THE STREET UNLESS DIRECTED OTHERWISE BY ENGINEER.
4. PROVIDE RESTRAINED JOINTS FOR FLUSHING HYDRANT ASSEMBLY.
5. PAINT FLUSHING HYDRANT GLOSS BLACK PER SPEC 02520. INSTALL DISK ON PUMPER NOZZLE AND LABEL "FOR FLUSHING ONLY".
6. IF WATER TRANSMISSION LINE IS PVC OR D.I. PIPE MATERIAL, INSTALL A D.I. TEE. IF WATER TRANSMISSION LINE IS STEEL OR CONCRETE CYLINDER PIPE MATERIAL, INSTALL A MANUFACTURER'S FLANGED TEE AT THE SPRING LINE.



STANDARD FLUSHING HYDRANT DETAIL

N.T.S.



STANDARD WATERLINE DETAILS

APPROVED BY: *Strandagiri*
DESIGN MANAGER

EFF. DATE: 12-22-2020 REF. NO. 22