



**FRONT VIEW**

**SIDE VIEW**

## **FLOWMETER ENCLOSURE ASSEMBLY**

NTS (NOTE 1)

### **NOTES:**

1. INSTALLATION OF FLOW METER ENCLOSURE IN THIS MANNER ONLY WHEN UNABLE TO MOUNT ON SCADA PANEL, DUE TO MANUFACTURER'S RECOMMENDATION OR DISTANCE FROM SCADA PANEL. IN ADDITION, THE INSTALLATION MUST BE APPROVED BY NHCRWA BEFORE USE.
2. FLOW METER TRANSMITTER TO BE MOUNTED IN SCADA CABINET



### **ELECTRICAL DETAILS**

APPROVED BY: *Shandagiri*  
DESIGN MANAGER

EFF. DATE: 12-22-2020 REF. NO. 107