



PRESSURE GROUT BEHIND
TUNNEL LINER

*SEE SPECIFICATION SECTIONS
02425 AND 02517

TUNNEL DETAIL

(FOR WATER MAINS 36 INCHES AND LARGER)

NOTES:

1. DETAIL IS FOR PRESTRESSED CONCRETE CYLINDER PIPE (STEEL PIPE AND D.I.P. ALTERNATE SIMILAR).
2. MINIMUM CLEARANCES SHOWN ON THE PLAN & PROFILE DRAWINGS ARE TO THE O.D. OF TUNNEL LINER. ADJUST PROFILE AS REQUIRED TO MAINTAIN CLEARANCES IDENTIFIED. NO SEPARATE PAY.
3. CONTRACTOR TO PROVIDE SUBMITTAL OF THE TUNNEL LINER DESIGN SIGNED AND SEALED BY A PROFESSIONAL ENGINEER.



TUNNEL & CASING DETAILS

APPROVED BY: *Shandagiri*
DESIGN MANAGER

EFF. DATE: 12-22-2020	REF. NO. 41
--------------------------	----------------