



SAMPLE FAUCET

SCALE: NTS

NOTES:

1. ALL EXTERIOR LINES 2" AND SMALLER SHALL BE INSULATED.
2. ADD SUPPORT AT LOCATION SHOWN. ADJUSTABLE STATION DETAIL, REF. NO. 88.
3. CONNECTION TO CONCRETE GROUND STORAGE TANK IS SHOWN. SEE REF. NO. 73, THIS SHEET FOR EXAMPLE OF CONNECTION TO STEEL GROUND STORAGE TANK.
4. PROVIDE COUPLINGS PER TECHNICAL SPECIFICATION SECTION 15155- "COUPLINGS AND COUPLING ADAPTERS."
5. REFER TO TECHNICAL SPECIFICATION SECTION 09905- "REPAINTING AND REPAIR OF EXISTING WATER FACILITIES" FOR METHODS TO REPAIR COATING ON GST.

DESIGN ENGINEER NOTES:

- A. DESIGN ENGINEER TO UPDATE MODEL NUMBERS IF SPECIFIED MODEL NO LONGER IS AVAILABLE.



GROUND STORAGE TANK RISER DETAIL

APPROVED BY: *Shandagiri*
DESIGN MANAGER

EFF. DATE: 12-22-2020 REF. NO. 72