


53A



53C

1. 3 BOLLARDS SHOULD BE PROVIDED IN TRIANGULAR PATTERN AROUND VENT PIPE OR ANODE PIPE.
2. 2 - 1 1/2" WIDE x 3/16" THICK GALVANIZED STEEL STRAPS SECURED W/ 5/8" DIA. S.S. BOLTS.
3. CLASS B CONCRETE WILL BE USED IN AND AROUND BOLLARDS.
4. SEE DETAIL 53B FOR LOCATION OF ONE BOLLARD AROUND VENT PIPE.
5. VERIFY THAT LOCATION OF SCREEN IS 1 FOOT ABOVE 500-YEAR FLOOD PLAIN ELEVATION OR 4 FEET ABOVE NATURAL GROUND WHICHEVER IS HIGHER.
6. PAINT ALL VENT PIPING AND BOLLARDS PER SPECIFICATION 09902 USING SHERWIN WILLIAMS ISLE OF PINES, 6461.