






No.	Date	Revisions	App.



- NOTES:
1. CONCRETE STRENGTH AT 28 DAYS,  $f_c=4,000$  psi
  2. STEEL REINFORCEMENT,  $f_y= 60,000$  psi
  3. ALL EXPOSED CORNERS SHALL BE CHAMFERED 1/2".



METER STATION & PRESSURE FLOW CONTROL – SLAB ON GRADE

APPROVED BY: 

DESIGN MANAGER

EFF. DATE: 12/22/2020

REF. NO. 69